



Office of the Principal / Member Secretary
ADARSHA VIDYALAYA, LOWAIRPOA
Affiliated to CBSE

VIII. & P.O.: Chandkhira, Dist.: Karimganj, Assam – 788725
Mobile : +91 9954031363 E-mail : avlowairpoa@gmail.com



CBSE Affiliation No.: 220012, CBSE School Code : 37197, DISE Code : 18220310624

Date : 30-10-2021

From: Dr. Biplab Karmakar, M.Sc., M.Ed., and Ph.D
Principal cum Member Secretary
Adarsha Vidyalaya, Lowairpoa

Undertaking of Fire Safety

In favour of the Chairman, CBSE, Shiksha Kendra- 2, Community Centre, Preet Vihar, New Delhi- 110092.

I, Dr. Biplab Karmakar, Principal, Adarsha Vidyalaya, Lowairpoa, Karimganj, Assam undertake that the Fire Safety Certificate will be uploaded as soon as it is issued by the competent authority as it has been applied vide application no. AV/LOWAIRPOA/MISC/2021/004/012 dated 19/10/2021

Enclo:

1. Reverent paper
2. Previous record regarding the same.


Principal

Adarsha Vidyalaya, Lowairpoa
Karimganj

Principal
Adarsha Vidyalaya, Lowairpoa
Dist. Karimganj, Assam



Office of the Principal / Member Secretary
ADARSHA VIDYALAYA, LOWAIRPOA
Affiliated to CBSE

Vill. & P.O.: Chandkhira, Dist.: Karimganj, Assam – 788725
Mobile : +91 0954031363 E-mail : avlowairpoa@gmail.com



CBSE Affiliation No.: 220012, CBSE School Code : 30161, DISE Code : 18220310624

Letter No.: AV/LOWAIRPOA/MISC/2021/004/012

Date: 19/04/2021

From,

Dr. Biplab Karmakar. M.Sc, M.Ed, Ph.D
Principal, Adarsha Vidyalaya, Lowairpoa

To

The Fire Station Officer, Patharkandi
Fire & Emergency Services
Sub- Application for Fire safety for our school

Sir,

With due respect and in the reference subject cited I would like to inform you that we are in need of Fire Safety Certificate for our school from fire and emergency service, Assam which is to be uploaded in CBSE Website for up gradation of our school to the senior secondary school. We have already installed 03 Nos of Fire Extinguisher at different points of our school building and one fire point (Sand) with three buckets. We will install more numbers of Fire Extinguishers in near future


Therefore, in the greater interest of the students, In would like to request you to provide the Fire Safety Certificate for school from Fire & Emergency Services

Copy to-

- 1.The Mission Director RMSA, Assam for her kind information
- 2.The Deputy Commissioner, Karimganj for his kind information
- 3.The Inspector of Schools,KDC, Karimganj, for his kind information
- 4.The Circle officer, Patharkandi cum Chairman, SMDC, for his kind information.
- 5.Office Copy

Received on
28/10/2021
Sub Officer
Patharkandi Fire & Emergency
Service Station
Dist. Karimganj, Assam

Yours faithfully,


Principal,
Adarsha Vidyalaya, Lowairpoa
Karimganj
Principal
Adarsha Vidyalaya, Lowairpoa
Dist. Karimganj, Assam

KARIMGANJ FIRE & EMERGENCY SERVICES STATION

MEMO NO. KXJ/F & ESS/16/315 /15 DATED: 21/6/2015

To, The principal
Model School, Lowairpoa,
Dist. Karimganj.

Sub: - Submission inspection report of your School (G+1st)

Sir,

With due respect and humble submission, I have visited and inspected at your Model School, Lowairpoa, Dist. Karimganj, Assam. and found the following particulars along with suggestion for implementation of fire prevention and means of escape measures in your building which are furnished below:

1. Name of the : Model School, Lowairpoa
2. Name of owner : RMSA, Assam.
3. Total Land Area : 16 bigahs.
4. Dag No. 338 (pt) Patta No. — Mauza: Maligaron
5. Total height of building : 22 feet (approx)
6. Surrounding property :
 - a) East : N.H. W
 - b) West : Forest
 - c) North : - do -
 - d) South : Lake
7. Total building: 4 nos. + 1 no. hostel
8. Area of each floor
 - (a) Ground floor : 4900 sq. feet
 - (b) 1st floor : — do —
 - (c) 2nd floor : —
 - (e) 3rd floor : —
9. Purpose of Utilization
 - (a) Ground floor : office room, class room, Library, Laboratory.
 - (b) 1st floor : class room, teacher room.
 - (c) 2nd floor : /
 - (d) 3rd floor : /

No. KXJ/F&ES/...../14

dated/2014.

To
The principal,
Model School, Lowaispoo,
Dist. Karimganj, Assam.

Ref :-

Sir,

With reference to the above, you are requested to implement the following addition of Fire preventive and means of escape measures in your Building for safety of lives and national property.

RECOMMENDATION OF FIRE PREVENTIVE AND MEANS OF ESCAPE MEASURES.


1. One Fire Point Consisting of 3 sand bucket, 3 Nos.
Water bucket 1 No. ceiling hook and 1 No. Fire Beater should be provided in front of the Building.
2. ABC or DCP Extinguisher of 5Kg ISI Mark Capacity should be provided in each of the floor of the building. The Extinguisher should be so distributed over each floor so that a person has to travel not more than 15 metres to reach the nearest Extinguisher.
3. Hose Reel should be provided in each floor of the building & hydrent line.
4. 1(one) Terrace tank should be provided at the terrace level of the buildings having capacity of 20,000.00 ltrs with pump 900/ min and underground water storage tank of capacity 50,000 ltrs in front of the building.
5. Manually operated electric alarm should be provided in the building.
6. Electric Wiring of the building should be either conduit/conceal type.

Contd.....P/2

7. Co₂ extinguisher of 4.5Kg. capacity should be provided near the main electricity panel Board.
8. A.F.F.F. extinguisher of 9 litres capacity should be provided near the generator room, lubricant storage room etc.
9. Lightning Conductor should be provided to protect the building from lightning disaster.
10. Electric wiring should be provided in conduit or concealed type. Approach road and entrance gate must be 12 feet wide to enable easy entry of Fire Service Vehicles.
11. Telephone No. of Local Fire Station should be stuck on the wall in easily visible places of the building (03843-262101).
12. At least two employees/staff must be trained to operate the Fire extinguisher in case of emergency.
13. To eliminate fire hazards, good house-keeping both inside and outside of the building to be strictly maintained.
14. Separate Electric circuit is to be maintained for stairway/corridor etc. of the building.

PLEASE DO NOT TREAT IT AS NOC FOR
FORMAL NOC WILL BE ISSUED ONLY AFTER IMPLEMENTATION OF
THE FIRE PREVENTIVE MEASURES AS PER SUGGESTION AND
RECEIVED OF COMPLAINT REPORT FROM YOUR END AND AFTER
SATISFACTORY INSPECTION REPORT OF TECHNICAL OFFICERS OF THIS DEPT.

Yours faithfully,


24/6/15
Station Officer
Karimganj Fire &
Emergency Services Station
Dist. Karimganj, Assam.

Memo No. KXJ/I & ESS/

Copy to :-

- 1) The Director, Fire & Emergency Service, Assam, Guwahati for favour of your kind information & necessary action.
- 2) The Deputy Commissioner, Karimganj, Assam for favour of your kind information & necessary action.

Yours faithfully,